

# FOUR SEASON HYBRID POWER SYSTEM TARGETING USING POWER PINCH ANALYSIS

MUHAMMAD IKMAL BIN AZMAN

UNIVERSITI TEKNOLOGI MALAYSIA

FOUR SEASON HYBRID POWER SYSTEM TARGETING USING POWER  
PINCH ANALYSIS

MUHAMMAD IKMAL BIN AZMAN

A project report submitted in partial fulfilment of the  
requirements for the award of the degree of  
Master of Science (*Energy Management*)

Faculty of Chemical and Energy Engineering  
Universiti Teknologi Malaysia

AUGUST 2017

*To my beloved parents,  
Azman Bin Ismail and Patimah Zahuran Binti Mohd Nor,  
for the encouragement and blessing all time as well as to  
my supervisor,  
Professor Sharifah and Dr. Ho Wai Shin  
for the guidance and support  
to my friends, for their unconditionally support  
and to all of my lecturers, siblings and those who help me throughout this project*

## **ACKNOWLEDGEMENT**

First and foremost, I would like to express my very special gratitude to my parents, Azman Bin Ismail and Patimah Zahuran Binti Mohd Nor for giving greatest support and motivation toward completing my project. I also would like to express greatest gratitude to my final year project supervisor, Professor Ir Dr Sharifah Rafidah Wan Alwi and Dr Ho Wai Shin for giving me this opportunity to handle this challenging project. They supervise and provide me guidance throughout the entire project research process, and also point out my mistakes in this project and my personal weakness so that I can improve myself for future challenges. Lastly, very big thanks to friends and people that helps me in my project.

## **ABSTRACT**

Energy exists in many different forms in nature but the most effective usage to human is electrical energy. Typically, electricity demand is higher in the winter than in the summer. Demand for electricity tends also to fluctuate over the course of the day, determined by human activity. This resulting in inefficient energy operation for the countries involved. Pinch analysis is a rigorous, structured approach for identifying inefficiencies in industrial process energy use. Power Pinch Analysis (PoPA) is an extension of the heat Pinch Analysis (PA). PoPA is used for the optimal Hybrid Power System (HPS) supply planning and demand management. This project involved the extended usage of PoPA in seasonal energy production planning. The result expected from this modelling study is successful of PoPA in order to tackle the optimization problem in energy production. As for the long term energy storage, it is necessary for the HPS in order to overcome problems in high energy demand seasons.

## ABSTRAK

Tenaga wujud dalam pelbagai bentuk dalam alam semula jadi tetapi penggunaan yang paling efektif untuk manusia adalah tenaga elektrik. Biasanya, permintaan elektrik adalah lebih tinggi pada musim sejuk berbanding musim panas. Permintaan untuk tenaga elektrik juga tidak menentu sepanjang hari, berdasarkan aktiviti manusia. Ini menyebabkan operasi tenaga yang tidak cekap bagi negara-negara yang terlibat. Analisis jepit adalah kukuh, pendekatan berstruktur untuk mengenal pasti ketidakcekapan dalam penggunaan proses tenaga dalam industri. Analisis kuasa jepit (PoPA) adalah lanjutan daripada Analisis haba jepit (PA). PoPA telah menyelesaikan perancangan bekalan system bekalan hybrid optimum (HPS) dan pengurusan permintaan. Projek ini melibatkan penggunaan lanjutan Pops dalam pengeluaran tenaga bermusim. Hasil dijangka daripada kajian model ini adalah kejayaan PoPA bagi menangani masalah pengoptimuman dalam pengeluaran tenaga. Untuk simpanan jangka masa panjang, adalah menjadi keperluan untuk HPS di negara bermusim untuk menangani masalah ketidakcukupan tenaga semasa musim yang memerlukan tenaga yang banyak.

## TABLE OF CONTENT

CHAPTER	TITLE	PAGE
	TITLE PAGE	i
	DECLARATION	ii
	DEDICATION	iii
	ACKNOWLEDGEMENT	iv
	ABSTRACT	v
	ABSTRAK	vi
	TABLE OF CONTENTS	vii
	LIST OF TABLES	xi
	LIST OF FIGURES	xiii
	LIST OF ABBREVIATIONS	xiv
	LIST OF SYMBOLS	xv
	LIST OF APPENDICES	xvi
<b>1</b>	<b>INTRODUCTION</b>	<b>1</b>
	1.1 Introduction	1
	1.2 Research Background	2
	1.3 Problem Statement	3
	1.4 Research Objectives	4

1.5	Research Scope	4
1.6	Significance of the Research	5
1.7	Report Outline	5
<b>2</b>	<b>LITERATURE REVIEW</b>	<b>6</b>
2.1	Introduction	6
2.2	Energy Demand Overview	7
2.2.1	Four Season Energy Demand	8
2.3	Renewable Energy	10
2.3.1	Solar	10
2.3.2	Wind	12
2.3.3	Biomass	14
2.3.4	Tidal	15
2.3.5	Geothermal	17
2.4	Energy Storage	18
2.4.1	Solid State Batteries	18
2.4.2	Flow Batteries	19
2.4.3	Flywheels	19
2.4.4	Compressed Air Energy Storage	20
2.4.5	Thermal	20
2.4.6	Pumped Hydro Energy Storage	20
2.5	Hybrid Power System	22
2.6	Power Pinch Analysis	23
2.7	Electric System Cascade Analysis	26
2.8	Research Gap	27
<b>3</b>	<b>METHODOLOGY</b>	<b>28</b>



3.1	Introduction	28
3.2	Research design and Procedure	28
3.3	Assumptions and Limitations	41
<b>4</b>	<b>RESULT AND DISCUSSION</b>	<b>42</b>
4.1	Introduction	42
4.2	Results of First Case Study	46
4.2.1	Seasonal Storage Power Cascade Table for CAES	46
4.2.2	Seasonal Storage Power Cascade Table for PHES	49
4.2.3	Seasonal Storage Power Cascade Table for Battery (Sodium Sulphur)	52
4.2.4	Seasonal Storage Power Cascade Table for Hydrogen	55
4.2.5	Seasonal Storage Power Cascade Table for Best Solution	58
4.3	Results of Second Case Study	61
4.3.1	Seasonal Storage Power Cascade Table for Storing Option	62
4.3.2	Seasonal Storage Power Cascade Table for Selling	66
4.4	Discussion	70
<b>5</b>	<b>CONCLUSION AND RECOMMENDATION</b>	<b>73</b>
5.1	Conclusions	73
5.2	Recommendation	74



## LIST OF TABLES

<b>TABLE NO.</b>	<b>TITLE</b>	<b>PAGE</b>
2.1	Comparison of Various Energy Storage.	21
2.2	Difference between PoPA and ESCA	26
3.1	Electricity Demand Profile	35
3.2	Power Generation Profile	36
3.3	Seasonal Storage Power Cascade Table	37
4.1	Electricity Demand Profile	43
4.2	Power Generation Profile	43
4.3	Seasonal Storage Power Cascade Table	44
4.4	Seasonal Storage Cascade Table for CAES	47
4.5	Economic Analysis of CAES Technology	49
4.6	Seasonal Storage Cascade Table for PHES	50
4.7	Economic Analysis of PHES Technology	52
4.8	Seasonal Storage Cascade Table for Battery	53
4.9	Economic Analysis of Battery Technology	55
4.10	Seasonal Storage Cascade Table for Hydrogen	56
4.11	Economic Analysis of Hydrogen Technology	58
4.12	Seasonal Storage Cascade Table for Best Solution	59
4.13	Economic Analysis of Best Solution	61
4.14	Seasonal Storage Cascade Table for Storing Option	63

4.15	Economic Analysis of Storing Option	65
4.16	Seasonal Storage Cascade Table for Selling Option	67
4.17	Economic Analysis of Selling Option	69
4.18	Summary Result for the First Case Study	71
4.19	Comparison of Storing and Selling Option	72

**LIST OF FIGURES**

<b>FIGURE NO.</b>	<b>TITLE</b>	<b>PAGE</b>
2.1	Great Britain Demand in Summer and Winter	8
2.2	Electricity Consumption of Hong Kong in 2006	9
2.3	Difference between solar thermal and solar PV	11
2.4	Effect of solar generation in two different season	12
2.5	Image of wind turbine	13
2.6	Effects of wind generation on different season	14
2.7	Performance Characteristic Graph by Each Long Term Energy Storage	22
2.8	Power Pinch Analysis Chronology	25
3.1	Operational Framework	30

## LIST OF ABBREVIATIONS

PoPA	-	Power Pinch Analysis
ESCA	-	Electric System Cascade Analysis
PV	-	Photovoltaic
CSP	-	Concentrating Solar Power
PA	-	Pinch Analysis
CAES	-	Compressed Air Energy Storage
PHES	-	Pump Hydro Energy Storage
kWh	-	kilowatt hour
RPM	-	Rotation Per Minute
AC	-	Alternating Current
DC	-	Direct Current

## LIST OF SYMBOLS

$DC_{s/d}$	-	DC electricity surplus/deficit
$AC_{converted}$	-	amount of DC converted from AC electricity surplus
$DC_{converted}$	-	amount of DC electricity surplus that will be converted to AC to satisfy the AC load demand
$S_t$	-	Storage capacity
$S_{t-1}$	-	Storage capacity at previous time interval
$\sigma$	-	Hourly self-discharge rate
$t$	-	Time
$T$	-	Duration of time
$\eta_I$	-	Inverter efficiency
$\eta_d$	-	Discharging efficiency of storage
$C_t$	-	Charging quantity
$\eta_c$	-	Charging efficiency
\$	-	United States Dollar

**LIST OF APPENDICES**

<b>APPENDIX</b>	<b>TITLE</b>	<b>PAGE</b>
A	Calculation of no long term energy storage	77
B	Calculation of economic analysis for first option	80
C	Calculation of economic analysis for second option	81



## **CHAPTER 1**

### **INTRODUCTION**

#### **1.1 Introduction**

Energy is the basic necessity for the economic development of a country. There are many functions necessary to present-day living disturbed if the supply of energy stops. It is practically impossible to estimate the actual magnitude of the part that energy has played in the building up of present-day civilisation. The availability of huge amount of energy in the modern times has resulted in a shorter working day, higher agricultural and industrial production, and better transportation facilities. There is a close relationship energy used per person and his standard of living. The greater the per capita consumption of energy in a country, the higher is the standard of living of its people.

Energy exists in many different forms in nature but the most effective usage to human is in form of electrical energy. The modern society is so much relying to the use of electrical energy until it has become a part and parcel of daily life. By current technologies, it is possible to convert electrical energy into any desired form. This has given electrical energy a place of one of the pride in the modern world. The survival of industrial projects and our modern social life depends primarily upon low cost and uninterrupted supply of electrical energy.

Typically, electricity demand is higher in the winter than in the summer. The peak demands in the summer are usually lower when compared to the peak demands of the winter and the low demands of the summer are low when compared to the low demands of the winter. Demand for electricity tends also to fluctuate over the course of the day, determined by human activity.

Human activity, which mainly measured in residential sector contributes most to the higher demand during winter compared to summer. This is because, during winter, people return home they will be turning on electrical equipment such as heater, lighting, televisions, and kettles and begin to start cooking dinner. Demand then begins to fall and drops off as people begin to retire to bed. Meanwhile, during summer, people return home when it is still light and perhaps a preference for cold beverages/food in the warmer weather. During evening, the household electricity use being lower in the summer because every usage at home in the evening will be counteracted by the switching off of air conditioning systems in shops and offices.

## **1.2 Research Background**

A Hybrid Power System (HPS) is a system that combines the use of intermittent electrical energy from various Renewable Energy (RE) sources including solar photovoltaic, wind, wave, biomass and geothermal with “purchased” or outsourced power that are either supplied from the grid or self-generated onsite using conventional fuel sources. The HPS is more suitable for industrial applications as compared to using individual RE that can either be too dependent on one RE source (e.g. in the case of biomass), or cater for small loads (i.e. in the case of solar). Less risk is taken by using HPS. The HPS is a step on tackling the problems facing by many countries in order to meet the demand of its user.

The energy usage for seasonal countries is not the same for each season. The difference in energy consumption during seasons will make the cost of electricity production to rise. This results in inefficient energy operation for the countries involved. Usually the countries that have four seasons will have trouble during the season of higher demand. Thus, this contributes to high electricity prices and higher risk of global warming.

Hence, a cost effective storage can be used to store energy produced in one season to be used later in higher demand season. PoPA is used in this study to cater the energy demand in four season country.

### **1.3 Problem Statement**

Given a set of demands and renewable energy sources which have different electricity profiles at different seasons, it is desired to determine the type and size of power storage and backup generator, as well as the potential mechanism of storing and utilisation of electricity to obtain the cost effective minimum outsource electricity target considering grid connected system.

Power pinch analysis has been previously developed in order to tackle the problem of energy production but its usage has been limited to the analysis of one season country only. This research extends the usage of PoPA for seasonal countries analysis in order to tackle the fluctuation problems of energy production.

## **1.4 Research Objective**

Based on the problem statement, finding the way to tackle the energy demand is crucial. Followings are the objectives of the research:

- (1) To develop extended power pinch analysis to cater for four season country.
- (2) To evaluate the appropriate long term seasonal storage system using PoPA
- (3) To evaluate the economics if hydrogen generated from RE should be stored and used in other seasons or sold for other purposes.

## **1.5 Research Scope**

The scope of the research simplified below:

- (1) State of the art review on power pinch analysis as well as the seasonal power sources and demands behaviour.
- (2) Developing step wise methodology for extended power pinch analysis for four season country.
- (3) Applying case study for seasonal country on the extended power pinch in order to find outsource energy and others.
- (4) Performing economic analysis on the system.

## **1.6 Significance of the Research**

This research will contribute to electricity saving and reducing its cost during high demand season. Also, the research is important for the country with four seasons to implement the suggested way based on the findings.

Also, the research can contribute to the extended knowledge of pinch analysis due to extended usage of power pinch analysis that is currently only on one season country. The research will contribute to the birth of expert in power pinch analysis on four season country.

## **1.7 Report Outline**

This report is divided into four chapters. Chapter One covers the introduction part of the project. This chapter also consist of six sub-chapters which is introduction, research background, problem statement, objectives, scope of the project and report outline. Chapter Two is a literature review on the Energy demand overview, renewable energy and energy storage. Besides that, it also shows the introduction of power pinch analysis method.

Next, Chapter Three is about methods and process of the project. The steps taken in this project is discussed and explains the assumptions and limitations of the research conducted. Then, Chapter Four is the result and discussion of the project.

## REFERENCES

- A. Ter-Gazarian. (1994). Energy Storage for Power Systems. *Iee*, 238, 55–145.
- Awad, M. M., Muzychka, Y. S., Azoumah, Y., Blin, J., Daho, T., Bejan, A., ... Radermacher, R. (2012). *Analysis of cumulative exergy consumption. International Journal of Energy Research* (Vol. 3).  
<https://doi.org/10.1002/er.4440110410>
- David Tan, A. K. S. (2011). Handbook for Solar Photovoltaic Systems. *Energy Market Authority, Singapore Publication*, 4–9.
- Energy, S. (2014). GB Electricity Demand Profiles , Summer vs Winter, (March), 2012–2015.
- International Energy Agency. (2013). *Renewable energy*.
- Kagel, A., Bates, D., & Gawell, K. (2007). A Guide to Geothermal Energy and the Environment, (April), 20–58.
- Kaltschmitt, M., Kaltschmitt, M., Streicher, W., Streicher, W., Wiese, A., & Wiese, A. (2007). *Renewable Energy - Technology, Economics and Environment. Technology*.
- Lam, J. C., Tang, H. L., & Li, D. H. W. (2008). Seasonal variations in residential and commercial sector electricity consumption in Hong Kong. *Energy*, 33(3), 513–523. <https://doi.org/10.1016/j.energy.2007.10.002>
- Melaina, M., & Nrel, M. P. (2013). Hydrogen Station Cost Estimates Comparing Hydrogen Station Cost Estimates Hydrogen Station Cost Estimates Comparing Hydrogen Station Cost Estimates, (September).
- Mohammad Rozali, N. E., Wan Alwi, S. R., Ho, W. S., Manan, Z. A., & Kleme??, J. J. (2016). Integration of diesel plant into a hybrid power system using power pinch analysis. *Applied Thermal Engineering*, 105, 792–798.  
<https://doi.org/10.1016/j.applthermaleng.2016.05.035>
- Mohammad Rozali, N. E., Wan Alwi, S. R., Manan, Z. A., & Kleme??, J. J. (2016a). Process Integration for Hybrid Power System supply planning and demand management ??? A review. *Renewable and Sustainable Energy Reviews*, 66,

- 834–842. <https://doi.org/10.1016/j.rser.2016.08.045>
- Mohammad Rozali, N. E., Wan Alwi, S. R., Manan, Z. A., & Kleme??, J. J. (2016b). Sensitivity analysis of hybrid power systems using Power Pinch Analysis considering Feed-in Tariff. *Energy*, 116, 1260–1268. <https://doi.org/10.1016/j.energy.2016.08.063>
- Nelson, V. (2009). *Wind Energy. Renewable Energy and the Environment. Undersea & hyperbaric medicine : journal of the Undersea and Hyperbaric Medical Society, Inc* (Vol. 38). Retrieved from <http://www.ncbi.nlm.nih.gov/pubmed/21882696>
- Rozali, N. E. M., & Yahaya, M. S. M. (2016). Study of the Effects of Seasonal Climate Variations on Hybrid Power Systems Using Power Pinch Analysis. *Procedia Engineering*, 148, 1030–1033. <https://doi.org/10.1016/j.proeng.2016.06.584>
- Salari, M., & Javid, R. J. (2016). Residential energy demand in the United States: Analysis using static and dynamic approaches. *Energy Policy*, 98, 637–649. <https://doi.org/10.1016/j.enpol.2016.09.041>
- Shin, W., Macchietto, S., Shiun, J., Hashim, H., Ab, Z., & Hui, W. (2016). Optimal scheduling of energy storage for renewable energy distributed energy generation system. *Renewable and Sustainable Energy Reviews*, 58, 1100–1107. <https://doi.org/10.1016/j.rser.2015.12.097>
- Swan, L. G., & Ugursal, V. I. (2009). Modeling of end-use energy consumption in the residential sector : A review of modeling techniques, 13, 1819–1835. <https://doi.org/10.1016/j.rser.2008.09.033>
- WORLD ENERGY COUNCIL. (2016). *World Energy Resources E-Storage 2016*.
- Nelson, V. (2009) *Wind Energy. Renewable Energy and the Environment, Undersea & hyperbaric medicine : journal of the Undersea and Hyperbaric Medical Society, Inc*. Available at: <http://www.ncbi.nlm.nih.gov/pubmed/21882696>.
- Kaltschmitt, M. et al. (2007) *Renewable Energy - Technology, Economics and Environment, Technology*.
- Twidell, J. and Weir, T. (2006) *Renewable Energy Resources, Management*. doi: 10.4324/9780203478721.